

2018年废水检测报告数据统计表																
	ph	色度(度)	悬浮物(mg/L)	COD(mg/L)	BOD5(mg/L)	氨氮(mg/L)	总氮(mg/L)	总磷(mg/L)	总氰化物(mg/L)	石油类(mg/L)	挥发酚(mg/L)	氟化物(mg/L)	总铜(mg/L)	总锌(mg/L)	总镍(mg/L)	
参考排放限值	6~9	80	100	200	50	20	-	1.5	1	-	2	20	0.5	5	-	
2018/1/23	7.76	1	4	10	5	3.17	9.13	0.98	0.003	0.04	0.01	0.01	0.04	0.12	0.08	
2018/2/1	7.64	1	5	35.7	1.6	0.284	4.67	0.94	0.013	0.04	0.01	2.17	0.07	0.13	0.07	
2018/3/1	7.62	1	8	41	2.5	0.785	6.47	0.81	0.011	0.04	0.01	1.78	0.07	0.18	0.11	
2018/4/3	7.57	1	6	20.4	4.3	0.97	6.35	0.69	0.005	0.06	0.01	1.36	0.05	0.13	0.05	
2018/5/7	7.38	1	7	28.8	5.1	0.53	5.39	0.89	0.002	0.04	0.01	1.11	0.25	0.23	0.1	
2018/6/13	7.06	1	6	16.4	1.9	0.41	4.1	0.64	0.002	0.04	0.01	1.09	0.04	0.1	0.08	
2018/7/2	7.43	1	8	24	5.2	0.84	3.82	0.6	0.002	0.07	0.01	2.12	0.03	0.11	0.06	
2018/8/8	8.1	1	4	23.1	4.3	0.02	5.12	0.82	0.004	0.11	0.01	4.83	0.03	0.1	0.03	
2018/9/12	7.66	1	4	25.8	6.7	0.85	4.64	0.65	0.003	0.08	0.01	4.64	0.04	0.07	0.03	
2018/10/16	7.76	1	10	30.7	7.6	0.18	2.61	0.96	0.002	0.04	0.01	4.86	0.11	0.096	0.083	
2018/11/19	7.38	1	6	21	2.9	1.18	5.02	0.96	0.003	0.06	0.01	3.12	0.05	0.082	0.049	
平均	7.578181818	1	6.181818182	25.17273	4.281818	0.838091	5.21090909	0.81272727	0.004545455	0.056363636	0.01	2.462727273	0.070909	0.122545455	0.067454545	